

Ice Fountain® Water District Quality On Tap Report - 2025

We're pleased to present you this year's annual water quality report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water system and protect our water resources. We are committed to ensuring the quality of your water. The water source is Ice Fountain® Spring, a ground water source that we have been using since May 1, 1999. After reviewing the test requirements handed down by the EPA for all water systems we are proud to report that our drinking water is safe and meets federal and state requirements. If you have any questions about this report or concerning your water utility please contact Casey Vannet, District Manager, at (541) 386-4299. You may also visit our website at www.icefountainwaterdistrict.com. We would be pleased to answer any questions you have. You can also attend a regularly scheduled Board Meeting on the third (3rd) Tuesday of every month at 4250 Barrett Drive, Hood River, Oregon at 12:00 noon. You may also attend the Board meetings virtually, please visit www.icefountainwaterdistrict.com for more information. Ice Fountain® Water District routinely monitors for constituents in your drinking water according to Federal and State Laws. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk. All sources of drinking water are subject to potential contamination by substances that are naturally occurring or manmade. These substances can be microbes, inorganic or organic chemicals and radioactive substances. The presence of contaminants does not necessarily indicate that the water posed a health risk. If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Ice Fountain Water District is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to two minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at www.epa.gov/safewater/lead

More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791. Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by crypto-sporidium and other microbiological contaminants can be obtained by calling the Safe Water Drinking Water Hotline at 1-800-426-4791.

Once again, as a team at Ice Fountain® Water District, we will continue to put forth our best effort to continue to provide you with a safe, clean water source. If you would like a copy of our test results they are available at the office located at 1375 San Giorgio Road in Hood River.

Thank you for your support and interest in your Water District.
Sincerely,

Ice Fountain® Water District Board and Staff

Water Quality Data Table

The Environmental Protection Agency regulates the frequency of sampling for various contaminants. The data presented in this table is from testing conducted in 2025

TERMS AND ABBREVIATIONS:

AL: Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLG's allow for a margin of safety.

MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLG's as feasible using the best available treatment technology.

LRL: Laboratory reporting limit: The lowest level the lab can test for.

UOM: Units of Measure

ND: None Detected.

ppb: Parts per billion, or micrograms per liter.

ppm: Parts per million, or milligrams per liter.

Contaminants (units)	MCLG	MCL	Max Detected	Sample Date	Violation	Typical Source
Nitrate (ppm)	10	10	ND	2025	No	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits

Microbiological Contaminants

Seven Samples are required to be collected monthly. * All of 2025 were None Detected

All lead and copper sample results were below the threshold set by the EPA for safe drinking water.

More detailed results are available upon request.

Sample Date	Chemical	Results	MCL	UOM
09/08/2025	Chloroform	ND	0.0010	mg/L
09/08/2025	Bromodichloromethane	ND	0.0010	mg/L
09/08/2025	Dibromochloromethane	ND	0.0010	mg/L
09/08/2025	Bromoform	ND	0.0010	mg/L
09/08/2025	Total THM	ND	0.0010	mg/L
09/08/2025	Total HAA5	ND	0.0010	mg/L
09/08/2025	Dibromoacetic Acid	ND	0.0010	mg/L
09/08/2025	Dichloroacetic Acid	ND	0.0010	mg/L
09/08/2025	Monobromoacetic Acid	ND	0.0010	mg/L
09/08/2025	Monochloroacetic Acid	ND	0.0020	mg/L
09/08/2025	Trichloroacetic Acid	ND	0.0010	mg/L
09/17/2025	1,2-Dibromo-3-chloropropane	ND	0.000202	mg/L
09/17/2025	1,2-Dibromoethane (EDB)	ND	0.000202	mg/L
09/17/2025	Chlordane	ND	0.000239	mg/L
09/17/2025	Endrin	ND	0.0000957	mg/L
09/17/2025	Heptachlor	ND	0.0000957	mg/L
09/17/2025	Heptachlor Epoxide	ND	0.0000957	mg/L
09/17/2025	Lindane (gamma-BHC)	ND	0.0000957	mg/L
09/17/2025	Methoxychlor	ND	0.000191	mg/L
09/17/2025	Polychlorinated biphenyls (PCBs)	ND	0.000239	mg/L
09/17/2025	Toxaphene	ND	0.000287	mg/L
09/17/2025	2,4,5-TP (Silvex)	ND	0.00500	mg/L
09/17/2025	2,4-D	ND	0.00200	mg/L
09/17/2025	Dalapon	ND	0.00500	mg/L
09/17/2025	Dinoseb	ND	0.00100	mg/L
09/17/2025	Pentachlorophenol (PCP)	ND	0.000500	mg/L
09/17/2025	Picloram	ND	0.00500	mg/L
09/17/2025	Benzene	ND	0.0005	mg/L
09/17/2025	Carbon tetrachloride	ND	0.0005	mg/L
09/17/2025	Chlorobenzene	ND	0.0005	mg/L
09/17/2025	1,2-Dichlorobenzene	ND	0.0005	mg/L
09/17/2025	1,4-Dichlorobenzene	ND	0.0005	mg/L
09/17/2025	1,2-Dichloroethane (EDC)	ND	0.0005	mg/L
09/17/2025	1,1-Dichloroethylene	ND	0.0005	mg/L
09/17/2025	cis-1,2-Dichloroethylene	ND	0.0005	mg/L
09/17/2025	trans-1,2-Dichloroethylene	ND	0.0005	mg/L
09/17/2025	Methylene chloride	ND	0.0005	mg/L
09/17/2025	1,2-Dichloropropane	ND	0.0005	mg/L
09/17/2025	Ethyl Benzene	ND	0.0005	mg/L
09/17/2025	Styrene	ND	0.0005	mg/L
09/17/2025	Tetrachloroethylene (PCE)	ND	0.0005	mg/L
09/17/2025	Toluene	ND	0.0005	mg/L
09/17/2025	1,2,4-Trichlorobenzene	ND	0.0005	mg/L
09/17/2025	1,1,1-Trichloroethane	ND	0.0005	mg/L
09/17/2025	1,1,2-Trichloroethane	ND	0.0005	mg/L
09/17/2025	Trichloroethylene	ND	0.0005	mg/L
09/17/2025	Vinyl chloride	ND	0.0005	mg/L

Sample Date	Chemical	Results	MCL	UOM
09/08/2025	Chloroform	ND	0.0010	mg/L
09/08/2025	Bromodichloromethane	ND	0.0010	mg/L
09/08/2025	Dibromochloromethane	ND	0.0010	mg/L
09/08/2025	Bromoform	ND	0.0010	mg/L
09/08/2025	Total THM	ND	0.0010	mg/L
09/08/2025	Total HAA5	ND	0.0010	mg/L
09/08/2025	Dibromoacetic Acid	ND	0.0010	mg/L
09/08/2025	Dichloroacetic Acid	ND	0.0010	mg/L
09/08/2025	Monobromoacetic Acid	ND	0.0010	mg/L
09/08/2025	Monochloroacetic Acid	ND	0.0020	mg/L
09/08/2025	Trichloroacetic Acid	ND	0.0010	mg/L
09/17/2025	1,2-Dibromo-3-chloropropane	ND	0.000202	mg/L
09/17/2025	1,2-Dibromoethane (EDB)	ND	0.000202	mg/L
09/17/2025	Chlordane	ND	0.000239	mg/L
09/17/2025	Endrin	ND	0.0000957	mg/L
09/17/2025	Heptachlor	ND	0.0000957	mg/L
09/17/2025	Heptachlor Epoxide	ND	0.0000957	mg/L
09/17/2025	Lindane (gamma-BHC)	ND	0.0000957	mg/L
09/17/2025	Methoxychlor	ND	0.000191	mg/L
09/17/2025	Polychlorinated biphenyls (PCBs)	ND	0.000239	mg/L
09/17/2025	Toxaphene	ND	0.000287	mg/L
09/17/2025	2,4,5-TP (Silvex)	ND	0.00500	mg/L
09/17/2025	2,4-D	ND	0.00200	mg/L
09/17/2025	Dalapon	ND	0.00500	mg/L
09/17/2025	Dinoseb	ND	0.00100	mg/L
09/17/2025	Pentachlorophenol (PCP)	ND	0.000500	mg/L
09/17/2025	Picloram	ND	0.00500	mg/L
09/17/2025	Benzene	ND	0.0005	mg/L
09/17/2025	Carbon tetrachloride	ND	0.0005	mg/L
09/17/2025	Chlorobenzene	ND	0.0005	mg/L
09/17/2025	1,2-Dichlorobenzene	ND	0.0005	mg/L
09/17/2025	1,4-Dichlorobenzene	ND	0.0005	mg/L
09/17/2025	1,2-Dichloroethane (EDC)	ND	0.0005	mg/L
09/17/2025	1,1-Dichloroethylene	ND	0.0005	mg/L
09/17/2025	cis-1,2-Dichloroethylene	ND	0.0005	mg/L
09/17/2025	trans-1,2-Dichloroethylene	ND	0.0005	mg/L
09/17/2025	Methylene chloride	ND	0.0005	mg/L
09/17/2025	1,2-Dichloropropane	ND	0.0005	mg/L
09/17/2025	Ethyl Benzene	ND	0.0005	mg/L
09/17/2025	Styrene	ND	0.0005	mg/L
09/17/2025	Tetrachloroethylene (PCE)	ND	0.0005	mg/L
09/17/2025	Toluene	ND	0.0005	mg/L
09/17/2025	1,2,4-Trichlorobenzene	ND	0.0005	mg/L
09/17/2025	1,1,1-Trichloroethane	ND	0.0005	mg/L
09/17/2025	1,1,2-Trichloroethane	ND	0.0005	mg/L
09/17/2025	Trichloroethylene	ND	0.0005	mg/L
09/17/2025	Vinyl chloride	ND	0.0005	mg/L